Manhole In	spection Summary	Manhole # S08YY_018MH
Printed On: 6/24	1/2010	Page 1 of 5
Inspection	☐ Is Incomplete Rating: 4) Poor	
Record Plat: 08	BYY Node: 018 Status: Found	Insp Date: 2/4/08 11:38 AM
Incomplete Cor	mments	Crew: BC JD
		Inspector: Chung
		Firm: URS
Location	Address: 2908 SILVER HILL AVE	Cross Street: GWYNN OAK AVE
Manhole	Type: Inline Location: Roadway	Ground Conditions: Wet
	Prev. Rehab Weather: Dry	Subject To Ponding: None
Comments	3 BROKEN PIPES, CRACKED BENCH W/	SOIL INFILTRATION
Cover	Shape: Circular Diameter: 26 (ir	
	Type: Sanitary Condition: Sound	Cover Material: Cast Iron
Properties:	☐ Bolted ☐ Vented ☐ Water Tight ☐	Water Tight Insert
Frame	Offset: 0 (in.) Condition: ✓ Sound	☐ Cracked ☐ Leaks
Chimney / Fra	me Adjustment 🗸 Exists Material: Brick	Parged Height: 4 (in.)
Condition:	☐ Sound ☐ Cracked ☐ Root Intrusion	✓ Loose Brick ✓ Deteriorated
Infiltration:	✓ None ☐ Joint ☐ Cracks ☐ Mortar [☐ Roots ☐ Wall
Corbel	Material: Brick Parged	Type: Concentric/Eccentric
Condition:	✓ Sound ☐ Cracked ☐ Root Intrusion [Loose Brick Deteriorated
Infiltration:	✓ None ☐ Joint ☐ Cracks ☐ Mortar	☐ Roots ☐ Wall
Barrel	Material: Brick Parged	
Shape:	Circular Diameter: 48 (in.) Length	: (in.)
Condition:	☐ Sound ☐ Cracked ☐ Root Intrusion [Loose Brick
Infiltration:	✓ None ☐ Joint ☐ Cracks ☐ Mortar	☐ Roots ☐ Wall
Bench	✓ Exists Material: Brick	☐ Parged
Condition:	☐ Sound ✓ Cracked ☐ Root Intrusion	✓ Deteriorated ✓ Leaks ✓ Debris
Channel	Material: Brick Parged	
Channel E	xposure: Fully Open Junc Dist: 0	nearest .5 ft. Azimuth:
Condition:	☐ Sound ✓ Cracked ☐ Root Intrusion	✓ Deteriorated ☐ Leaks ✓ Debris
Steps	Count: 3 Missing: 0 Corroded	
Surcharge	Evidence Of Surcharge Depth: (ft.)	☐ Active Surcharge Present

Manhole	Inspection	Summary
---------	------------	----------------

Manhole # S08YY_018MH

Printed On: 6/24/2010 Page 2 of 5

Location View	Top View
GRADE ADJUSTMENT	Defect 5
	BENCH DAMAGED
Defect 1	Defect 4
3 O'CLOCK PIPE DAMAGED	3 O' CLOCK & 6 O'CLOCK PIPE SEAL DAMAGED

Manhole Inspection Summary	Manhole # S08YY_018MH	
Printed On: 6/24/2010	Page 3 of 5	
Defect 3	Defect 2	
DEBRIS/MUD ON THE BENCH	CHANNEL CRACKED	

Manhole Inspection Summary	Manhole # S08YY_018MH
Printed On: 6/24/2010	Page 4 of 5
8 in. Circular Gravity Sewer Pipe Out @ 12 O'Clock	12 O'Clock Outflow
BROKEN PIPE	
Pipe Height: 8.4 (in.) Rod and Bar (Angled)	Drop: None
Pipe Material: Clay Pipe Lined Invert Depth: 7.10 (ft.) Flow Characteristics: Slow	
Deposits: None Mud Sludge Debris Grease	
Silt Depth: (in.) Deposits Extent:	Connects To: County (No manhole in GIS)
Infiltration: None Pipe Seal Cond: Broken	Possible Illicit Connection
8 in. Circular Gravity Sewer Pipe In @ 3 O'Clock BROKEN PIPE	3 O'Clock Inflow
Pipe In @ 3 O'Clock	
Pipe In @ 3 O'Clock BROKEN PIPE	3 O'Clock Inflow Drop: None
Pipe In @ 3 O'Clock BROKEN PIPE Pipe Height: 8.4 (in.) Rod and Bar (Angled)	
BROKEN PIPE Pipe Height: 8.4 (in.) Rod and Bar (Angled) Pipe Material: Clay	
BROKEN PIPE Pipe Height: 8.4 (in.) Rod and Bar (Angled) Pipe Material: Clay Pipe Lined Invert Depth: 6.90 (ft.) Flow Characteristics: Slow	

Manhole Inspection Summary	Manhole # S08YY_018MH
Printed On: 6/24/2010	Page 5 of 5
6 in. Circular Gravity Sewer Pipe In @ 6 O'Clock	6 O'Clock Inflow
BROKEN PIPE	
Pipe Height: 6 (in.) Rod and Bar (Angled) Pipe Material: Clay Pipe Lined Invert Depth: 6.70 (ft.) Flow Characteristics: None	Drop: None
Deposits: ☐ None ☐ Mud ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐ ☐	
Silt Depth: 3 (in.) Deposits Extent: Medium	Connects To: House connection / Service line
Infiltration: None Pipe Seal Cond: Broken	Possible Illicit Connection
6 in. Circular Gravity Sewer Pipe In @ 7 O'Clock	7 O'Clock Inflow
Pipe Height: 6 (in.) Rod and Bar (Angled) Pipe Material: Clay	Drop: None
Invert Depth: 6.70 (ft.) Flow Characteristics: None	
Deposits: None Mud Deposits Grease Silt Depth: 4 (in.) Deposits Extent: Medium	Connects To: House connection / Service
Infiltration: None Pipe Seal Cond: Sound	line ☐ Possible Illicit Connection